

# Ontario Fire Code Monthly Inspections

Name of Business: \_\_\_\_\_

Year: \_\_\_\_\_

	Jan.	Feb.	Mar.	Apr.	May	June	July	Aug.	Sept.	Oct.	Nov.	Dec.
Fire Extinguishers												
Emergency Lights												

Monthly Inspections on the above listed equipment are to be performed by the owner or designate and recorded for Fire Department Review

Inspection Criteria:

Fire Extinguishers - Pressure gauge in operating range; nozzle free of debris; mounted properly; inspection tag :

Emergency Lights - Illuminate when power is interrupted